

## State Water Resources Control Board

July 20, 2018

(Via email and Certified Mail)

**CERTIFIED MAIL**

**NO. 7017 2680 0000 6195 9081**

Mr. Shea Eccleston  
Senior Public Works Manager  
City of Glendale Public Works  
541 West Chevy Chase Drive  
Glendale, California 91204  
[seccleston@glendaleca.gov](mailto:seccleston@glendaleca.gov)

**SUBJECT: NOTICE OF VIOLATION - NO FURTHER ACTION REQUIRED;  
UNDERGROUND STORAGE TANK SYSTEMS AT GLENDALE PUBLIC  
WORKS, 541 WEST CHEVY CHASE DRIVE, GLENDALE**

Dear Mr. Eccleston:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the USTs at your facility on June 26, 2018, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	<b>Failure to Meet Designated Operator (DO) Inspection Requirements</b> – On October 2, 2017, the L3 sensor had a sensor out alarm. The October monthly DO report did not document this alarm in the report.	North Diesel	October 1, 2017	October 31, 2017	23 CCR 2715 (c)(1)

To our knowledge, the violation above has been corrected. Therefore, no further action is required at this time.

If you have any questions, please contact me at (916) 341-5551, or by email at [amantha.henkel@waterboards.ca.gov](mailto:amantha.henkel@waterboards.ca.gov).

Sincerely,



Amantha Henkel  
Senior Environmental Scientist  
UST Enforcement Unit  
**Office of Enforcement**

cc: See next page

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

cc: *(via email only)*

Mr. Michael Lunsford  
Assistant Environmental Technician  
City of Glendale Public Works  
[mlunsford@glendaleca.gov](mailto:mlunsford@glendaleca.gov)

Ms. Lucy Varpetian  
Senior Assistant City Attorney  
City of Glendale  
[lvarpetian@glendaleca.gov](mailto:lvarpetian@glendaleca.gov)

Mr. Gevorg Nazaryan  
Fire Inspector  
Glendale City Fire Department  
[gnazaryan@glendaleca.gov](mailto:gnazaryan@glendaleca.gov)

Mr. Jovan Diaz  
Principal Fire Environmental Safety Specialist  
Glendale City Fire Department  
[jodiaz@ci.glendale.ca.us](mailto:jodiaz@ci.glendale.ca.us)

Mr. Adam Levitan  
Deputy Attorney General  
Office of the Attorney General  
[adam.levitan@doj.ca.gov](mailto:adam.levitan@doj.ca.gov)

Mr. David Boyers  
Assistant Chief Counsel  
Office of Enforcement  
[david.boyers@waterboards.ca.gov](mailto:david.boyers@waterboards.ca.gov)